



THE CITY OF SAN DIEGO

City of San Diego
Planning & Development Review
Building Development Review
1222 First Avenue • MS-401
San Diego, CA 92101
(619) 446-5400

Building Newsletter 7-6

Ventilation for Ranges or Hot Plates in Dwelling Units

Interpretations of State and Local Building Codes
1998 California Building Code: Chapter 7
Revision Date: July 1999

Page 1 of 1

I. Ventilation Not Required

The Mechanical Code does not require ventilation for gas and electric ranges or hot plates in dwelling units.

II. Standards If Provided

Where such ventilation is provided, however, the following standards must be met.

A. Ducts used for domestic kitchen range ventilation

shall be of metal with smooth interior surfaces and they must comply with the Mechanical Code.

B. Exhaust ducts shall terminate outside the building and shall be equipped with back draft dampers.

C. Listed hoods must comply with manufacturer's recommendations.